

Common Setting

Time (?) 2025-01-28 10:31:

PV Input Mode (?) 4: Two MPPT conn

Model

Battery Type (?) 2: Lithium

Lead-acid Capacity (?) 0: 50Ah

Lithium Type (?) 1

Normal / Standby (?)

Battery ECO Enable (?)

Restart Inverter (?)

Buzzer Enable (?)

Application Setting

EPS Voltage Set(V) (?) 120/240

EPS Frequency Set(Hz) (?) 60

AC Input Range (?) 1: UPS(Utility Rang)

PV Grid Off (?)

PV Arc

PV Arc Fault Clear

RSD

N-PE Bond (?)

AC First (?)

AC first Start Time 1 (?) 00 : 00

AC first Start Time 2 00 : 00

AC first Start Time 3 00 : 00

AC first End Time 1 (?) 00 : 00

AC first End Time 2 00 : 00

AC first End Time 3 00 : 00

Parallel Settings

Set System Type (?) No Parallel

Battery Shared (?)

Set Composed Phase (?) Phase U

Grid Loss Warning Clear

Charge Setting

Charge Current Limit(Adc) (?) 125

Charge Current Limit(Adc) (?) 25 Set

Lead Acid

Charge Voltage(V) (?) 57.4 Set

Floating Voltage(V) (?) 54 Set

Equalization Voltage(V) (?) 58.8 Set

Equalization Period(Days) (?) 30 Set

Equalization Time(Hours) (?) 0 Set

AC Charge

AC Charge Based On (?) Disable Set AC Charge Battery Current(A) 30 Set

AC Charge Start Time 1 00 : 00 Set AC Charge Start Time 2 00 : 00 Set AC Charge Start Time 3 00 : 00 Set

AC Charge End Time 1 00 : 00 Set AC Charge End Time 2 00 : 00 Set AC Charge End Time 3 00 : 00 Set

AC Charge Start Battery Voltage(V) (?) 46.4 Set

AC Charge End Battery Voltage(V) (?) 48 Set

AC Charge Start Battery SOC(%) (?) 30 Set

AC Charge End Battery SOC(%) (?) 100 Set

Generator Charge

Generator Charge Type (?) Battery SOC (Set

Generator Charge Battery Current(A) (?) 100 Set

Generator Charge Start Battery Voltage(V) (?) 46.4 Set

Generator Charge End Battery Voltage(V) (?) 48 Set

Generator Charge Start Battery SOC(%) (?) 20 Set

Generator Charge End Battery SOC(%) (?) 100 Set

Max. Generator Input Power(W) (?) 7370 Set

Generator Boost Enable **Disable**

Discharge Setting

Discharge Control (?) SOC (Accordi Set

Discharge Current Limit(Adc) (?) 140 Set

Battery Warning Voltage(V) (?) 44 Set

Battery Warning SOC(%) (?) 19 Set

Discharge Cut-off Voltage(V) (?) 42 Set

Discharge Cut-off SOC(%) (?) 15 Set

On Grid EOD Voltage(V) (?) 42 Set

On Grid EOD SOC(%) (?) 15 Set

AC Couple

AC Couple (?) Enable **Disable**

AC Couple Start Volt(V) 50 Set

AC Couple Start SOC(%) 50 Set

AC Couple End Volt(V)

54

Set

AC Couple End SOC(%)

90

Set

Smart Load

Smart Load (?)

Enable

Disable

Start PV Power(kW) (?)

0.5

Set

Grid Always On (?)

Enable

Disable

Smart Load Start Volt(V)

54

Set

Smart Load Start SOC(%)

90

Set

Smart Load End Volt(V)

48

Set

Smart Load End SOC(%)

60

Set

Other Setting

Fan 1 Max Speed(%) (?)

70

Set

Fan 1 speed slope

Default

New Slope

Fan 2 Max Speed(%) (?)

70

Set

Fan 2 speed slope

Default

New Slope

Battery

Read

Restart Battery Module 0

Restart Battery Module 1

Restart Battery Module

Reset

All to Default

Reset